



Declaration of Conformity

Issued by Manufacturer
Hoffman Enclosures, Inc. dba Pentair Equipment Protection 2100 Hoffman Way
Anoka, Minnesota 55303-1745, U.S.A.
 declare at our sole responsibility, that these devices are designed and constructed according to
 the fundamental safety and health requirements.

Enclosure Models: AWDH****N4, APWK**NF, APWK**NFSS, AWDH****N4SS, APWK**NFM (Bulletin A80W)

Equipment Description: Hoffman Polycarbonate/ Mild/Stainless Steel Window Kits

Enclosure Rating : NEMA / UL / cUL Type 3R(SS), 4, 4X(SS & NFM) 12, 13 (NF)

Enclosure Certification: UL508A Listed E61997

File #E61997 Vol. 2 Sec. 7 Page 1 Issued: 1991-04-09
 and Report Revised: 2014-07-26

DESCRIPTION

PRODUCT COVERED:

USR, CSR - Component, Steel Window Kits, Cat. Nos. APWK followed by -53NF, 95NF, 133NF, 138NF, 175NF, -711NF, -715NF, -720NF, -724NF, -729NF, 1711NF, 2315NF, 2919NF or 3523NF.

Stainless Steel Window Kits, Cat. Nos. APWK-53NFSS, -95NFSS, -133NFSS, -175NFSS, -138NFSS, -711NFSS, -715NFSS, -720NFSS, -724NFSS, -729NFSS, -1711NFSS, -2315NFSS, -2919NFSS, -3523NFSS.

EMWK Window Kit - Sizes up to and including 20 x 19 in., Cat. Nos. EMWK****, were **** are combination of number or letters or both, may have SS suffix for stainless steel frame.

Nonmetallic Window Kits, Cat. Nos. APWK, followed by 53, 95, 138 or 175, followed by NFM.

Hinged Window Kits, Cat. Nos. APWK followed by 1212H, 1612H, 2016H, 2020H, 2420H, or 3024H.

Grommeted Window Kit - Sizes up to and including 48 by 24 in., Type 12 only, Cat. Nos. AGRWXXXX.

Applicable Standards: UL508A Industrial Control Panel Enclosure
 UL 50 Enclosures for Electrical Equipment, Non-Environmental Considerations
 UL 50E Enclosures for Electrical Equipment, Environmental Considerations
 cUL to CSA C22.2 No. 94.1 and 94.2
 NEMA250 Enclosures for Electrical Equipment (1000 Volts Maximum)

Authorized by:

Glen Kampa

12/1/2015 (today's date)

Glen Kampa

Date

Senior Regulatory Engineer

Subject to Change Without Notice

CERTIFICATE OF COMPLIANCE

Certificate Number 20121102 – E61997
Report Reference E61997 - 19981104
Issue Date 2012-NOVEMBER-02

Issued to: PENTAIR TECHNICAL PRODUCTS
2100 HOFFMAN WAY
ANOKA, MN 55303 USA


This is to certify that representative samples of Industrial Control Panels
Types 3, 3R, 4, 4X, 12, and 12K enclosures and external field installed accessory kits.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 508A, "Industrial Control Panels" and CSA-C22.2 No. 14, "Industrial Control Equipment."

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

