

CERTIFICATE OF COMPLIANCE

Certificate Number 20160912-E10514
Report Reference E10514-19691216
Issue Date 2016-SEPTEMBER-12

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
3940 MARTIN LUTHER KING DR
ST LOUIS MO 63113

This is to certify that representative samples of OUTLET BOXES FOR USE IN HAZARDOUS LOCATIONS
See the addendum page for models

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 1203, "Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations" and ANSI/UL 50, "Enclosures for Electrical Equipment"

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20160912-E10514
Report Reference E10514-19691216
Issue Date 2016-SEPTEMBER-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models:

Conduit boxes for use in Class I, Groups C and D; Class II, Groups E, F and G hazardous locations with the designations and conduit size as indicated below.

Series GE - Types GET and GEX, followed by -1 or -2 may be followed by conduit size 1/2 or 3/4 in.

Series GEM - Types GEMC, GEMCF, GEMCA, GEME, CEMEA, GEML, GEMLA, GEMLB, GEMLF, GEMN, GEMT, GEMTA, GEMTF, GEMX, GEMXA and GEMXF, followed by -1 or -2, may be followed by M. Conduit size 1/2 or 3/4 in.

Conduit boxes for use in Class I, Groups B, C and D; Class II, Groups E, F and G hazardous locations with the designations and conduit size as indicated below.


Series GEC - Types GECC, GECL, GECTA, GECE, GECT, GECX and GECXA followed by -1 or -2, with integral unions, conduit sizes 1/2 or 3/4 in. Types GECET, GECEAT, GECCT, GECCAT, GECCTF, GECLAT, GECLBT, GECLT, GECLTF, GECNT, GECTAT, GECTT, GECCA, GECTTF, GECXAT, GECXT and GECXTF, followed by -1 or -2, may be followed by M. Conduit size 1/2 or 3/4 in.

Series GEC – Types GECET, GECEAT, GECCT, GECCAT, GECCTF, GECLAT, GECLBT, GECLT, GECLT, GECLTF, GECNT, GECTAT, GECTT, GECTTF, GECXAT, GECXT and GECXTF, followed by -1 or -2, followed by 6TB. Conduit size 1/2 or 3/4 in.

Series GEC – Type GECCT, GECET, GECEAT, GECCAT, GECCTF, GECLAT, GECLBT, GECLT, GECLTF, GECNT, GECTAT, GECTT, GECTTF, GECXAT, GECXT and GECXTF followed by -3 may be followed by M. Conduit size 1 in.

Series GEC – Types GECCT, GECET, GECEAT, GECCAT, GECCTF, GECLAT, GECLBT, GECLT, GECLTF, GECNT, GECTAT, GECTT, GECTTF, GECXAT, GECXT and GECXTF followed by -3, followed by 6TB. Conduit size 1 in.

Series SPJ followed by five or six digit number, may be followed by additional letters and number.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

