



中国国家强制性产品认证证书

证书编号: 2007010303245539

委托人名称、地址

施耐德(北京)中低压电器有限公司
北京经济技术开发区凉水河二街2号

生产者(制造商)名称、地址

P T Schneider Electric MFG Batam
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

生产企业名称、地址

P T Schneider Electric MFG Batam
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

产品名称和系列、规格、型号

安全模块

XPS-AC, AF, AFL, AK, AR, AV, BF, CM, DMB, DME, MP, TSA, TSW, VC, ATE, VNE;
XPS-AF, AFL, AK, AV, BF, CM, DMB, DME, MP, TSA, TSW, VC, VNE: Ithe: 2.5A;
AC-15: Ue/Ie: AC240V/0.75A; DC-13: Ue/Ie: DC24V/1.5A; XPS-AC: Ithe: 2.5A;
AC-15: Ue/Ie: AC240V/0.75A; DC-13: Ue/Ie: DC24V/2A; XPS-AR: Ithe: 5A; AC-
15: Ue/Ie: AC240V/1.5A; DC-13: Ue/Ie: DC24V/2A; XPS-ATE: Ithe: 2.5A; AC-
15: Ue/Ie: AC240V/0.75A; DC-13: Ue/Ie: DC24V/1A;

产品标准和技术要求

GB 14048.5-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求,特发此证。

发证日期: 2015年02月27日

有效期至: 2020年02月27日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期: 2007年08月27日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2007010303245539

NAME AND ADDRESS OF THE APPLICANT

Schneider (Beijing) Medium & Low Voltage Co., Ltd.
No. 2, Liang Shui He 2nd Street, Beijing Economic Technological
Development Area

NAME AND ADDRESS OF THE MANUFACTURER

P T Schneider Electric MFG Batam
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

NAME AND ADDRESS OF THE FACTORY

P T Schneider Electric MFG Batam
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

NAME, MODEL AND SPECIFICATION

Safety module

XPS-AC, AF, AFL, AK, AR, AV, BF, CM, DMB, DME, MP, TSA, TSW, VC, ATE, VNE;
XPS-AF, AFL, AK, AV, BF, CM, DMB, DME, MP, TSA, TSW, VC, VNE: Ithe: 2.5A;
AC-15: Ue/Ie: AC240V/0.75A; DC-13: Ue/Ie: DC24V/1.5A; XPS-AC: Ithe: 2.5A;
AC-15: Ue/Ie: AC240V/0.75A; DC-13: Ue/Ie: DC24V/2A; XPS-AR: Ithe: 5A; AC-
15: Ue/Ie: AC240V/1.5A; DC-13: Ue/Ie: DC24V/2A; XPS-ATE: Ithe: 2.5A; AC-
15: Ue/Ie: AC240V/0.75A; DC-13: Ue/Ie: DC24V/1A;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Feb.27,2015 Date of expiry: Feb.27,2020

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Aug.27,2007

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1031117



中国国家强制性产品认证证书

附录:

第 1 页 共 3 页

证书编号: 2007010303245539

纸号: 1031117

XPS-AC, AF, AFL, AK, AR, AV, BF, CM, DMB, DME, MP, TSA, TSW, VC, ATE, VNE

XPS-AF, AFL, AK, AV, BF, CM, DMB, DME, MP, TSA, TSW, VC, VNE:

Ithe: 2.5A; AC-15: Ue/Ie: AC240V/0.75A; DC-13: Ue/Ie: DC24V/1.5A;

XPS-AC:

Ithe: 2.5A; AC-15: Ue/Ie: AC240V/0.75A; DC-13: Ue/Ie: DC24V/2A;

XPS-AR:

Ithe: 5A; AC-15: Ue/Ie: AC240V/1.5A; DC-13: Ue/Ie: DC24V/2A;

XPS-ATE:

Ithe: 2.5A; AC-15: Ue/Ie: AC240V/0.75A; DC-13: Ue/Ie: DC24V/1A;

型号解释:

XPS-	$\frac{AC}{I}$	$\frac{1}{II}$	$\frac{3}{III}$	$\frac{2}{IV}$	$\frac{1}{V}$	$\frac{P}{VI}$
------	----------------	----------------	-----------------	----------------	---------------	----------------

XPS-安全模块

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 3 页

证书编号: 2007010303245539

纸号: 1031117

I - 监测类型和输出回路数量

- AC: 用于急停开关和限位开关的监控. 3NO.
- AF: 用于急停开关和限位开关的监控. 3NO.
- AFL: 用于急停开关和限位开关和光幕的监控. 3NO
- AK: 用于急停开关、限位开关、安全地毯和边沿开关或光幕的监控. 3NO+1NC
- AR: 用于急停开关和限位开关或光幕的监控. 7NO+2NC
- ATE: 用于急停开关和限位开关的监控. 2NO 瞬时+3NO 延时
- AV: 用于急停开关和限位开关的监控. 3NO 瞬时+3NO 延时
- BF: 用于双手控制台的监控. 2NO
- CM: 用于对射光电开关的监控. 2NO
- DMB: 用于磁性开关的监控. 2NO
- DME: 用于磁性开关的监控. 2NO
- MP: 用于多功能开关的监控. 3NO 瞬时+3NO 延时
- TSA: 用于启动延时的监控. 1NO 带延时+2NC 带延时
- TSW: 用于启动脉冲的监控. 1NO 带脉冲+2NC
- VC: 用于使能开关的监控. 2NO
- VNE: 用于电动机零速检测. 1NO+1NC

II - 供电模式

- 1 - DC
- 3 - AC (50/60Hz)
- 5 - AC (50/60Hz) / DC

III - 电源电压

- 1 - 24 V
- 3 - 48 V
- 4 - 115 V
- 5 - 120 V
- 6 - 110 V

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 3 页 共 3 页

证书编号: 2007010303245539

纸号: 1031117

IV - 内部版本号
7 - 230 V
1-3 位数字表示内部逻辑的版本号
V - 输出
1 位数字表示输出的个数
VI - 可选

LF- 低速频率
HS - >60Hz 电机(仅对 XPS-VNE)
P - 独立的可拆卸的接线端子
Txxx - 内部延时出厂预设值 (例如: T250=250 ms)

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

