

Certificate of Compliance

Certificate: 1380287 (LR 44087-116) **Master Contract:** 225619

Project:

1961548

Date Issued:

2007/11/28

Issued to:

Telemecanique/Schneider Electric

Industries SAS

BP 660

Zone Industrielle No. 3 L'Isle d'Espagnac, 16340

France

Attention: Mr. Jean-Pierre Laidet

The products listed below are eligible to bear the CSA Mark shown



Issued by:

Jean-Claude Chow, ing.

Authorized by: Helene Vaillancourt, **Operations Manager**

Helin Vaillanows

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary **Devices**

Part-A: Auxiliary Devices, 16 mm line, Type 4, 4X and 13 enclosures:

- Push buttons, Cat No. XB6-AA, -AS, -CA or -DA; pilot lights, Cat No. XB6-AV, -CV or -DV; illuminated push buttons and selectors, Cat Nos. XB6-AE, -AF, -AW, -AK, -CE, -CF, -CW, -CK, -DE, -DF, -DK or -DW; key switches, Cat No. XB6-AG, -CG or -DG; selector switches, Cat No. XB6-AD, -CD or -DD; both followed by a three or four numbers and/or letters suffix and rated B300, R300.
- Contact blocks, Cat No. ZB6 followed by E or Z, followed by 1 or 2, followed by A, B, D or E, rated B300, R300.



Certificate: 1380287 (LR 44087-116) **Master Contract:** 225619

Project: 1961548 **Date Issued:** 2007/11/28

Pilot light blocks, Cat No. ZB6 followed by E or Z, followed by B, G, H or M, followed by one digit, followed by A or B. LED type: 12-24V ac/dc or 48/120V ac or 230V ac; neon type: 230V ac max; incandescent type: 24V max, 0.6W max.

- Illuminated push buttons/selector blocks, Cat No. ZB6 followed by Z, followed by B, G, H or M, followed by a two digit number, followed by B or E. LED type: 12-24V ac/dc or 48/120V ac or 230V ac; neon type: 230V ac max; incandescent type: 24V max, 0.6W max.
- Operating heads, Cat No. ZB6 followed by A, C or D, followed by a letter, followed by one digit or one letter may be followed by 1 through 7.
- Accessory kits, Cat No. ZB6-Y followed by a three digit number.

Part-B: Auxiliary devices, 22 mm line, electrical blocks and accessories for printed circuit board connection:

- Contact blocks, Cat. No. ZBE-701, -702, rated B300, R300.
- Contact blocks, Cat. No. ZBE-7016, -7026, rated 24 V, 100 mA resistive.
- Pilot light blocks, Cat. No. ZBV-B followed by suffixes, LED Type 24V ac/dc.
- Accessory kits, Cat. No. ZBZ-010, ZBZ-010S, ZBZ-011, ZBZ-012, ZB4-BZ079, ZB5-AZ079.

Note: These devices are certified for use in other certified equipment where the suitability of the combination is determined by CSA International.

APPLICABLE REQUIREMENTS

CSA-C222 No. 14-05 - Industrial Control Equipment

CAN/CSA-C222 No. 94-M91 - Special Purpose Enclosures